

J&K LAKES AND WATERWAYS DEVELOPMENT AUTHORITY
RESEARCH & MONITORING DIVISION, MISKEEN BAGH, KHANYAR, SRINAGAR

MICROBIOLOGICAL RESULT OF SAMPLES COLLECTED ON 12.07.2019

Parameter	Unit	Hazratbal		Habak		Laam		Brari Nambal		Nallah Amir Khan		Norms as per NGT Order
		Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	
Fecal Coliform	Colonies / 100ml	2.6x10 ⁵	1600	2.5x10 ⁵	1450	2.0x10 ⁵	950	2.5x10 ⁵	950	1.7x10 ⁵	900	Desirable :100 Permissible :230