

J&K LAKES AND WATERWAYS DEVELOPMENT AUTHORITY

RESEARCH & MONITORING DIVISION, MISKEEN BAGH, KHANYAR, SRINAGAR

MICROBIOLOGICAL RESULT OF SAMPLES COLLECTED ON 16.06.2020

Parameter	Unit	Hazratbal		Habak		Laam		Norms as per NGT Order
		Raw	Final	Raw	Final	Raw	Final	
Fecal Coliform	Colonies / 100ml	---	---	---	800	---	670	Desirable :100 Permissible :230

J&K LAKES AND WATERWAYS DEVELOPMENT AUTHORITY
RESEARCH & MONITORING DIVISION, MISKEEN BAGH, KHANYAR, SRINAGAR

MICROBIOLOGICAL RESULT OF SAMPLES COLLECTED ON 07.07.2020

Parameter	Unit	Hazratbal		Habak		Laam		Brari Nambal		Brari Nambal (Old)		Nallah Amir Khan		Norms as per NGT Order
		Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	
Fecal Coliform	Colonies / 100ml	---	---	---	---	---	700	---	750	---	3000	---	650	Desirable :100 Permissible :230