

J&K LAKES AND WATERWAYS DEVELOPMENT AUTHORITY.

Research & Monitoring Division, Miskeen Bagh, Srinagar.

Physico-chemical analysis report of different STPs as on 06-02-2021.

Parameters	Units	Hazratbal		Habak		Laam		Brarinambal LDA		Brarinambal UEED		Nallah Amir Khan		Norms as per NGT	Permissible limits as per CPCB
		Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final		
Air Temperature	°C	10.1		10.7		10.3		8.2		8.1		8.1		--	--
W. Temp.	°C	9.0	9.3	8.1	7.8	8.6	8.3	7.4	6.5	7.4	6.8	9.8	8.1	--	5°C above receiving water body
pH	--	7.3	7.5	7.1	7.4	7.2	7.6	7.1	7.3	7.2	7.6	7.4	7.6	5.5-9.0	5.5-9.0
Dissolved Oxygen	mg/l	0.2	5.0	0.2	4.8	0.6	5.8	0.4	6.8	0.3	3.6	0.8	6.7		--
Ammonical Nitrogen	mg/l	11.9	9.3	12.6	9.5	10.2	9.1	9.9	2.2	9.4	7.3	9.9	1.4	TOTAL NITROGEN : 10	50
Total Phosphorous	mg/l	2.3	1.0	3.0	1.0	2.0	0.9	3.1	0.9	2.9	1.8	2.5	0.7	1.0 as T.P	5.0
T.S.S	mg/l	229	38	275	42	216	40	248	26	270	115	195	25	20	100
Fecal Coliform	Col/100 ml	-	400	-	425	-	440	--	450	--	2700	-	450	Desirable =100 Permissible =230	-

Note: - Samples for BOD Estimation under incubation.