



**J&K Pollution Control Board**  
Rajbagh, Srinagar Kashmir

Report No:- PCB/ROK/W.Lab/AR/20-21/82

Date 02/01/2021

**Analysis Report**

S.no	Parameter	STP NALLAH AMIR KHAN			STP BARINAMBAL LAWDA			STP BARINAMBAL UEED			Permissible limits as per genral standards for discharge of environmental pollutants
		RAW	FINAL	% TREATMENT	RAW	FINAL	% TREATMENT	RAW	FINAL	% TREATMENT	
Date of Sampling		29-12-2020			29-12-2020			29-12-2020			
1	Air Temperature	8.00			9.20			9.20			
2	Water Temperature	10.6	8.6		8.4	8.5		8.4	8.5		5°C above receiving water body.
3	pH	7.25	7.54		7.31	7.52		7.20	7.4		5.5 to 9.0
4	Dissolved Oxygen	0.00	5.5		0.40	6.1		0.30	2.2		-
5	Chemical Oxygen Demand	526.50	61.00	88.41	381.50	53.40	86.00	350.9	198.3	43.49	-
6	Biochemical Oxygen Demand for 3days at 27°C	155.00	14.1	90.90	116.60	13.0	88.85	116.60	54.6	53.17	30.0
7	Phosphate(PO4-P)	1.806	0.582	67.77	1.953	0.493	74.76	1.907	1.351	29.16	5.0
8	Ammonical Nitrogen (NH3-N)	10.492	2.181	79.21	9.777	2.573	73.68	9.714	8.96	7.74	50.0
9	Chloride	62.0	60.0	-	64.0	60.0	-	64.0	60.0	-	1000.0
10	Total Suspended Solids	-	25.0	-	-	22.0	-	-	115.0	-	100.0
11	Total Dissolved Solids	519.0	442.0	-	440.0	408.0	-	456.0	440.0	-	2100

% of Treatment should be= 90%

*It is advised that treated water from the STPs should be utilized for activities like irrigation, construction, industrial use etc instead of discharging it directly into the water bodies so that water bodies can be prevented from further deterioration*

All values are in mg/l except p H, & Temperature

Note :- This analysis report is confined only to the samples analysed

Sample Collected by

Analysed by

I/C Water Lab





**J&K Pollution Control Board**  
Rajbagh, Srinagar Kashmir

Report No:-PCB/ROK/W.Lab/AR/20-21/81

Date 02/01/2021

*Analysis Report*

S.no	Parameter	STP NISHAT LAAM			STP HABAK			STP HAZRATBAL			Permissible limits as per general standards for discharge of environmental pollutants
		RAW	FINAL	% TREATMENT	RAW	FINAL	% TREATMENT	RAW	FINAL	% TREATMENT	
<b>Date of Sampling</b>		<b>29-12-2020</b>			<b>29-12-2020</b>			<b>29-12-2020</b>			
1	<b>Air Temperature</b>	7.70			7.60			7.60			
2	<b>Water Temperature</b>	10.3	10.8	—	9.0	8.9	—	10.2	10.0	—	5°C above receiving water body.
3	<b>pH</b>	7.10	7.27	—	7.34	7.38	—	7.31	7.4	—	<b>5.5 to 9.0</b>
4	<b>Dissolved Oxygen</b>	0.60	4.0	—	0.50	4.7	—	0.50	4.6	—	—
5	<b>Chemical Oxygen Demand</b>	389.1	76.3	<b>80.39</b>	274.6	114.4	<b>58.34</b>	282.3	91.5	<b>67.59</b>	—
6	<b>Biochemical Oxygen Demand for 3days at 27°C</b>	125.00	18.6	<b>85.12</b>	88.60	28.60	<b>67.72</b>	84.60	20.1	<b>76.24</b>	<b>30.0</b>
7	<b>Phosphate(PO4-P)</b>	1.588	0.652	<b>58.94</b>	1.736	0.687	<b>60.43</b>	1.587	0.653	<b>58.85</b>	<b>5.0</b>
8	<b>Ammonical Nitrogen (NH3-N)</b>	9.797	8.55	<b>12.73</b>	9.568	8.79	<b>8.18</b>	9.855	8.534	<b>13.40</b>	<b>50.0</b>
9	<b>Chloride</b>	58.0	44.0	—	54.0	58.0	—	46.0	54.0	—	<b>1000.0</b>
10	<b>Total Suspended Solids</b>	—	28.0	—	—	36.0	—	—	30.0	—	<b>100.0</b>
11	<b>Total Dissolved Solids</b>	330.0	326.0	—	418.0	430.0	—	407.0	410.0	—	<b>2100</b>

% age Treatment should be= 90%

*It is advised that treated water from the STPs should be utilized for activities like irrigation, construction, industrial use etc instead of discharging it directly into the water bodies so that water bodies can be prevented from further deterioration*

*All values are in mg/l except p H, & Temperature*

*Note :- This analysis report is confined only to the samples analysed*

Sample Collected by

Analysed by

I/C Water Lab