

J&K LAKES AND WATERWAYS DEVELOPMENT AUTHORITY.

Research & Monitoring Division, Miskeen Bagh, Srinagar.

BOD status of different STPs as on 13-01-2021.

Parameters	Units	Hazratbal		Habak		Laam		Brarinambal LDA		Brarinambal UEED		Nallah Amir Khan		Norms as per NGT	Norms As pre CPCB
		Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final		
BOD	mg/l	133	32	159	51	139	31	175	22	163	65	131	21	10	30

BOD status of different STPs as on 14-01-2021.

Parameters	Units	Hazratbal		Habak		Laam		Brarinambal LDA		Brarinambal UEED		Nallah Amir Khan		Norms as per NGT	Norms As pre CPCB
		Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final		
BOD	mg/l	110	25	125	34	105	28	112	30	150	70	140	18	10	30