

J&K LAKES AND WATERWAYS DEVELOPMENT AUTHORITY.

Research & Monitoring Division, Miskeen Bagh, Srinagar.

BOD status of different STPs as on 15-01-2021.

Parameters	Units	Hazratbal		Habak		Laam		Brarinambal LDA		Brarinambal UEED		Nallah Amir Khan		Norms as per NGT	Norms As pre CPCB
		Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final		
BOD	mg/l	124	33	145	53	115	23	117	21	155	67	136	19	10	30

BOD status of different STPs as on 16-01-2021.

Parameters	Units	Hazratbal		Habak		Laam		Brarinambal LDA		Brarinambal UEED		Nallah Amir Khan		Norms as per NGT	Norms As pre CPCB
		Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final		
BOD	mg/l	105	23	136	33	97	17	107	11	141	35	172	26	10	30