

J&K LAKES AND WATERWAYS DEVELOPMENT AUTHORITY.

Research & Monitoring Division, Miskeen Bagh, Srinagar.

BOD status of different STPs as on 18-01-2021.

Parameters	Units	Hazratbal		Habak		Laam		Brarinambal LDA		Brarinambal UEED		Nallah Amir Khan		Norms as per NGT	Norms As pre CPCB
		Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final		
BOD	mg/l	122	32	131	37	117	24	136	18	156	65	145	17	10	30

BOD status of different STPs as on 19-01-2021.

Parameters	Units	Hazratbal		Habak		Laam		Brarinambal LDA		Brarinambal UEED		Nallah Amir Khan		Norms as per NGT	Norms As pre CPCB
		Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final	Raw	Final		
BOD	mg/l	168	30	123	34	98	24	118	20	115	46	125	21	10	30